



MINUTES OF THE BOARD OF SUPERVISORS  
COUNTY OF LOS ANGELES, STATE OF CALIFORNIA

Sachi A. Hamai, Executive Officer-  
Clerk of the Board of Supervisors  
383 Kenneth Hahn Hall of Administration  
Los Angeles, California 90012

At its meeting held October 14, 2008, the Board took the following action:

47-A

The following statement was entered into the record for Supervisor Yaroslavsky:

“On Friday, October 3, 2008 a ‘Boil Water Order’ was issued for Camp David Gonzales, a Probation Camp located in the unincorporated Malibu area. The Order was issued because eight out of thirteen water samples collected in September 2008 from the water distribution system at Camp Gonzales tested positive for Total Coliform during both routine and repeat testing.

“On Saturday, October 4, 2008, five repeat samples were taken and tested. Of these, two tested positive for Total Coliform. The water at Camp Gonzales is supplied by the Las Virgenes Municipal Water District. The water is stored in two tanks located on the Camp premises. The water supply is utilized for drinking, cooking and personal hygiene. In response to the Boil Water Order, bottled water is being issued to the wards and boiled or bottled water is being used for cooking. However, as of Friday, October 10, 2008, the underlying problems have not been resolved and the Boil Water Order remains in place.

“Several theories have been advanced as to the genesis of this problem, including a lack of regular cleaning and testing of the water tanks, the availability of chlorinators within the tanks, and the availability of appropriate mechanisms to ensure that the chlorine is properly circulated within the tanks; as well as the possibility of a cross-connection between the potable and reclaimed water lines servicing the Camp.

“Responsibility for this situation rests with the Internal Services Department as well as with Probation and Public Health. All three Departments, together with the Chief Executive Office, must resolve this problem immediately and take steps to ensure that water supplied to this and all other County Probation Camps is always pure and safe to drink.”

(Continued on Page 2)

47-A (Continued)

Tom Tindall, Director of Internal Services, presented a verbal report on the high bacterial counts in the water supply at Camp David Gonzales which has necessitated the imposition of a Boil Water Order for over one week, how this problem arose, how it is being resolved, and what steps are being taken to ensure that it does not reoccur; and responded to questions posed by the Board. Dr. Jonathan E. Fielding, Director of Public Health, also responded to questions posed by the Board.

After discussion, on motion of Supervisor Yaroslavsky, seconded by Supervisor Antonovich, unanimously carried, the report was received and filed.

09101408\_47-A

Copies distributed:

- Each Supervisor
- Chief Executive Officer
- County Counsel
- Chief Probation Officer
- Director of Internal Services
- Director of Public Health