



(310) 305-9503 • 13837 Fiji Way, Marina del Rey, CA 90292 • beaches.lacounty.gov

Caring for Your Coast

Gary Jones
Director

Kerry Silverstrom
Chief Deputy

John Kelly
Deputy Director

Brock Ladewig
Deputy Director

February 3, 2015

**Addendum #2 to Invitation for Bids for
As-Needed Septic Tank Maintenance Services
IFB #DBH57**

The Department of Beaches and Harbors issues Addendum Two to the As-Needed Septic Tank Maintenance Services IFB # DBH57, which was released on January 12, 2015.

As indicated in the IFB, Section 1.5, County Rights and Responsibilities, the County may amend the IFB by written addendum. This addendum contains portions of the Statement of Work that have been amended, specifically, Sections 6.0 SCOPE OF MAINTENANCE – MICROSEPTIC SEPTIC SYSTEM MODEL ES-12 and 7.0 SCOPE OF MAINTENANCE – ADVANTEX SEPTIC SYSTEM MODEL AX-100.

Thank you for your interest in our Invitation for Bids for As-Needed Septic Tank Maintenance Services. As a reminder, Bids are due on February 12, 2015, by 2:00 p.m. Pacific Standard Time, and should be delivered to: 13837 Fiji Way, Marina del Rey, CA 90292.

Very truly yours,

GARY JONES, DIRECTOR

Miguelangel Tamayo,
Administrative Services Manager I

The information hereunder supersedes any other information previously provided.

Amendments to Statement of Work

Section 6.3.1, of the Statement of Work is deleted and replaced with the following; Section 6.3.6 is added to Section 6.3:

6.3 Quarterly Services

6.3.1 Septic Tanks

Contractor shall perform scheduled preventive maintenance as recommended by the manufacturer. If needed, maintenance shall be performed on a monthly basis. This includes, but is not limited to, cleaning, lubricating, inspecting, testing, sampling and adjusting the septic system. In addition, the contractor shall inspect all risers for the following:

- Water level
- Sludge thickness and consistency
- Clearance of all obstructions
- Scum thickness and consistency
- Liquid levels
- Pumps floats
- Pump amperage
- Flow rate
- Plumbing Tee's cleared of obstacles

6.3.6 Alkalinity and Feed Equipment

- Inspect Pump Operation (Clean if necessary)
- Inspect Mixing Unit
- Check chemical level (add soda ash when necessary)

**Section 7.3.1, of the Statement of Work is deleted and replaced with the following;
Section 7.3.7 is added to Section 7.3:**

7.3 Quarterly Services

7.3.1 Septic Tanks

Contractor shall inspect all risers in the primary and secondary side of the septic tank. Inspection shall include, but not limited to:

- Water level
- Sludge thickness and consistency
- Scum thickness and consistency
- Liquid levels
- Pumps floats
- Pump amperage
- Flow rate
- Clearance of all obstructions
- Plumbing Tee's cleared of obstacles

7.3.7 Alkalinty and Feed Equipment

- Inspect Pump Operation (Clean if necessary)
- Inspect Mixing Unit
- Check chemical level (add soda ash when necessary)