



COUNTY OF LOS ANGELES

Internal Services Department

1100 North Eastern Avenue
Los Angeles, California 90063



Dave Lambertson
Director

To enrich lives through effective and caring service.

Telephone: (323) 267-2101
FAX: (323) 264-7135

December 30, 2004

To: Each Supervisor
From: Dave Lambertson
Director 
Subject: **RECENT STORM DAMAGE**

I want to inform your Board of some facility problems created by the recent heavy storms. As a result of the excessive rain and wind, there were fifty-one leak calls that ISD roofers responded to. Although the majority of the calls were minor repairs with no damage, there are nine locations where damage occurred and follow-up work is underway.

For your review I have attached a spreadsheet that provides you with the location and status of the nine facilities referenced above. If further damage occurs with the rain forecasted for the coming days, I will provide you with updated information.

Should you have any questions, please feel free to contact me, or your staff may contact Tim Braden at (323) 267-3445.

DL:tb

Attachments

c: David E. Janssen
ISD Board Deputies

ISD
 Facilities Operations Service
 Recent Storm Damage Log
 December 30, 2004

Department	Address	Problem	Status
BOS / CAO	KHHOA 500 W. Temple, LA	Water leaking in rooms 291, 293, 187, and B-87	Water entering building from planter. Roofers responded, assessing repair options; custodial vacuumed water
		Water leaking into rooms 750, 754	Repaired expansion joints and roof drain
District Attorney	Hall of Records 320 W. Temple, LA	Water entering first and third floors. Drains cannot handle large amounts of water during heavy downpours	Water cleaned up; assessing possibility of increasing drain size
Superior Courts	Edelman Children's Court 201 Center Plaza, Montebello	Water entering entrances and County Counsel's area in basement	Water cleaned up; assessing options for repair
Community and Senior Services	Altadena Community Center 560 E. Mariposa, Altadena	Water leaking in lobby, kitchen, and lunch areas	Water cleaned up
Superior Courts	Burbank Courts 300 E. Olive Ave., Burbank	Water entering basement in lock up area	Water cleaned up; assessing options for repair
Public Social Services / Probation	DPSS / Probation 1326 / 1330 W. Imperial Hwy., LA	Roof leaks throughout building	Water cleaned up; roof completely worn out; roof replacement required
Public Library	Hawthorne Library 12700 S. Grevillea Ave., Hawthorne	Water entering building through roof	Water cleaned up; one roof drain cleared, assessing possibility of increasing one roof drain size
Community and Senior Services	ELA Neighborhood Service Center 133 N. Sunol Dr., ELA	Water entering building through roof	Water cleaned up; ceiling and carpet being repaired
Internal Services Department	1100 N. Eastern	Hillside erosion	Temporary measures being taken to prevent further damage; budget estimate underway for long term action